


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Sigen EV AC charger
Name and address of the applicant	Shanghai SIGEN New Energy Technology Co., Ltd Room 514, 5th Floor, No. 175 Weizhan Road, Lingang New Area, China (Shanghai) Pilot Free Trade Zone, 201306 Shanghai China
Name and address of the manufacturer	Shanghai SIGEN New Energy Technology Co., Ltd Room 514, 5th Floor, No. 175 Weizhan Road, Lingang New Area, China (Shanghai) Pilot Free Trade Zone, 201306 Shanghai China
Name and address of the factory	Shanghai Sigeyuan Intelligent Technology Co., Ltd Room 513, 5th Floor, No. 175, Weizhan Road, Lingang New Area, China (Shanghai) Pilot Free Trade Zone, Shanghai, 201306 China
<i>When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	Product data Ratings: AC Input: 220/380V~240/415V, max. 32A, 50/60Hz, 3 phases AC Output: 220/380V~240/415V, max. 32A, 50/60Hz, 3 phases Max. Power: 22kW, -30~55°C, IP65 AC Input: 220V~240V, max. 32A, 50/60Hz, 1 phase AC Output: 220V~240V, max. 32A, 50/60Hz, 1 phase Max. Power: 7,68kW, -30~55°C, IP65
Trademark / Brand (if any)	 sigenergy
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Sigen EVAC XXXXXXXX
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61851-1:2017 National differences: BE, CH, DK, ES, FR, GB, IT, NL, SE
As shown in the Test Report Ref. No.	6168878.51A

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 3 January 2024

Signature: May Liu