

## EC DECLARATION OF CONFORMITY

Enphase Energy, Inc.  
1420 North McDowell Blvd  
Petaluma, CA 94954  
USA

Enphase Energy, SAS  
905 rue d'Espagne  
BP 128  
69125 LYON Aéroport Saint Exupéry  
FRANCE

declare under our sole responsibility that the product identified as:

### Q-RELAY-3P-INT

to which this declaration relates is in conformity with the following harmonized standards:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2001 + AC: 2001	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

following the provisions of the following EU Directives:

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Signed on behalf of Enphase Energy, Inc.

29 June 2018  
Christchurch, New Zealand



Manuel Shimasaki  
Director, Global Certification