



Product Service

Attestation of Conformity

No. N8A 099333 0066 Rev. 21

Holder of Attestation: **LONGi Green Energy Technology Co., Ltd.**

No. 388, Middle Hangtian Road
Chang'an District
710100 Xi'an City, Shaanxi
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061700516-29

Date, 2023-11-16

(Zhulin Zhang)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 099333 0066 Rev. 21

Model(s):

LR6-72HV-xxxM, (xxx=335-360 in step of 5)
 LR6-60HV-xxxM, (xxx=280-300 in step of 5)
 LR6-72PH-xxxM, (xxx=340-380 in step of 5)
 LR6-60PH-xxxM, (xxx=285-315 in step of 5)
 LR6-72PH-xxxM, (xxx=365-395 in step of 5)
 LR6-72HIH-xxxM, (xxx=365-395 in step of 5)
 LR6-60HPH-xxxM, (xxx=300-325 in step of 5)
 LR6-60HIH-xxxM, (xxx=300-325 in step of 5)
 LR6-72OPH-xxxM, (xxx=385-415 in step of 5)
 LR6-60OPH-xxxM, (xxx=335-365 in step of 5)
 LR6-72HPH-xxxMC, (xxx=375-390 in step of 5)
 LR6-60HPH-xxxMC, (xxx=305-325 in step of 5)
 LR4-72HPH-xxxM, (xxx=420-465 in step of 5)
 LR4-72HIH-xxxM, (xxx=420-465 in step of 5)
 LR4-60HPH-xxxM, (xxx=350-380 in step of 5)
 LR4-60HIH-xxxM, (xxx=350-380 in step of 5)
 LR4-72ZPH-xxxM, (xxx=420-435 in step of 5)
 LR4-60ZPH-xxxM, (xxx=350-365 in step of 5)
 LR6-60ZPH-xxxM, (xxx=330-355 in step of 5)
 LR4-78ZPH-xxxM, (xxx=455-485 in step of 5)
 LR5-72HPH-xxxM, (xxx=525-575 in step of 5)
 LR5-72HPH-xxxMa, (xxx=525-575 in step of 5)
 LR5-66HPH-xxxM, (xxx=480-530 in step of 5)
 LR5-66HPH-xxxMa, (xxx=480-530 in step of 5)
 LR4-66HPH-xxxM, (xxx=395-415 in step of 5)
 LR4-66HIH-xxxM, (xxx=395-415 in step of 5)
 LR5-72HIH-xxxM, (xxx=525-575 in step of 5)
 LR5-66HIH-xxxM, (xxx=480-530 in step of 5)
 LR5-78HPH-xxxM, (xxx=575-595 in step of 5)
 LR5-78ZPH-xxxM, (xxx=565-585, in step of 5)
 LR4-50HPH-xxxM, (xxx=305-320, in step of 5)
 LR4-66HTB-xxxM, (xxx=410-430 in step of 5)
 LR4-60HTB-xxxM, (xxx=370-390 in step of 5)
 LR5-54HPH-xxxM, (xxx=395-435 in step of 5)
 LR4-66HTH-xxxM, (xxx=420-440 in step of 5)
 LR4-60HTH-xxxM, (xxx=380-400 in step of 5)
 LR5-54HIH-xxxM, (xxx=395-435 in step of 5)
 LR5-72HTH-xxxM, (xxx=540-600 in step of 5)
 LR5-66HTH-xxxM, (xxx=495-550 in step of 5)
 LR5-54HTH-xxxM, (xxx=405-450 in step of 5)
 LR5-54HTB-xxxM, (xxx=400-440 in step of 5)
 LR5-60HPH-xxxM, (xxx=435-480 in step of 5)
 LR5-60HIH-xxxM, (xxx=435-480 in step of 5)
 LR5A-54HAH-xxxM, (xxx=425-445 in step of 5)
 LR5B-60HAH-xxxM, (xxx=425-445 in step of 5)
 LR5-72HPH-HD-xxxM, (xxx=525-575 in step of 5)
 LR5-72HPH-xxxMc, (xxx=525-575 in step of 5)
 LR5-66HPH-xxxMc, (xxx=480-530 in step of 5)
 LR5-72HTH-xxxMc, (xxx=540-600 in step of 5)
 LR5-66HTH-xxxMc, (xxx=495-550 in step of 5)
 LR5-72HGh-xxxM, (xxx=550-595 in step of 5)
 LR5-72HTHF-xxxM, (xxx=540-600 in step of 5)
 xxx stands for rated output power at STC

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 099333 0066 Rev. 21

Parameters:

| | |
|-------------------------|--|
| Fire Safety Class: | Class C according to UL790 |
| Safety Class: | Class II |
| Maximum System Voltage: | 1500V DC |
| Test Laboratory: | Yangzhou Opto-Electrical Products Testing Institute. No.10 West Kaifa Road, Yangzhou 225009 Jiangsu, P.R. China |
| Construction: | Framed, with Junction box, cable and connector. |

Tested according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®